**Cylindrical Photoelectric Sensors** 

# BRQ Series (side sensing type) INSTRUCTION MANUAL

Autonics

Thank you for choosing our Autonics product.

Read and understand the instruction manual and manual thoroughly before using the product.

For your safety, read and follow the below safety considerations before using. For your safety, read and follow the considerations written in the instruction manual, other manuals and Autonics website.

Keep this instruction manual in a place where you can find easily.

The specifications, dimensions, etc. are subject to change without notice for product improvement. Some models may be discontinued without notice. Follow Autonics website for the latest information.

# Safety Considerations

• Observe all 'Safety Considerations' for safe and proper operation to avoid hazards.

• A symbol indicates caution due to special circumstances in which hazards may occur.

Warning Failure to follow instructions may result in serious injury or death.

- 01. Fail-safe device must be installed when using the unit with machinery that may cause serious injury or substantial economic loss. (e.g., nuclear power control, medical equipment, ships, vehicles, railways, aircraft, combustion apparatus, safety equipment, crime/disaster prevention devices, etc.) Failure to follow this instruction may result in personal injury, economic loss or fire.
- 02. Do not use the unit in the place where flammable/explosive/corrosive gas, high humidity, direct sunlight, radiant heat, vibration, impact or salinity may be present.

Failure to follow this instruction may result in explosion or fire. 03. Do not disassemble or modify the unit.

- Failure to follow this instruction may result in fire
- 04. Do not connect, repair, or inspect the unit while connected to a power source.

Failure to follow this instruction may result in fire

05. Check 'Connections' before wiring.

Failure to follow this instruction may result in fire.

#### ▲ Caution Failure to follow instructions may result in injury or product damage.

01. Use the unit within the rated specifications.

ailure to follow this instruction may result in fire or product damage 02. Use a dry cloth to clean the unit, and do not use water or organic solvent. Failure to follow this instruction may result in fire

#### **Cautions during Use**

- Follow instructions in 'Cautions during Use'. Otherwise, It may cause unexpected accidents.
- When connecting an inductive load such as DC relay or solenoid valve to the output, remove surge by using diodes or varistors.

Use the product after 0.5 sec of the power input.

When using a separate power supply for the sensor and load, supply power to the sensor first.

- The power supply should be insulated and limited voltage/current or Class 2, SELV power supply device.
- Wire as short as possible and keep it away from high voltage lines or power lines to prevent surge and inductive noise.
- When using switching mode power supply (SMPS), ground F.G. terminal and connect a condenser between 0V and F.G. terminal to remove noise.
- When using a sensor with a noise-generating equipment (e.g., switching regulator, inverter, and servo motor), ground F.G. terminal of the equipment.
- This unit may be used in the following environments.
- Indoors (in the environment condition rated in 'Specifications')
- Altitude max. 2,000 m
- Pollution degree 3
- Installation category II

#### Product Components

| Sensing type           | Through-beam                | Polarized retroreflective | Diffuse reflective |  |
|------------------------|-----------------------------|---------------------------|--------------------|--|
| Product components     | Product, instruction manual |                           |                    |  |
| Reflector              | -                           | MS-2S                     | -                  |  |
| Adjustment screwdriver | ×1                          | ×1                        | ×1                 |  |
| M18 fixing nut         | × 4                         | × 2                       | × 2                |  |


# **Ordering Information**

This is only for reference, the actual product does not support all combinations. For selecting the specified model, follow the Autonics website.

| BRQ 0 0 0 - 0   | <b>5 6 7 8</b> - <b>0</b> - <b>0</b>   |  |
|---|--|--|
| Material     P: Plastic   | <b>Output</b><br>T: Solid state (transistor)   |  |
| <b>e</b> Sensing direction<br>S: Side   | Emitter/Receiver     No mark: Integrated type 1: Emitter 2: Receiver                 |  |
| Sensing distance<br>Number: Sensing distance (unit: mm)<br>Number+M: Sensing distance (unit: m) | <b>③ Appearance</b><br>A: Standard   |  |
| Sensing type     T: Through-beam     P: Polarized retroreflective     D: Diffuse reflective     | <b>O Connection</b><br>No mark: Cable type<br>C: Connector type                      |  |
| G Power supply<br>D: 10 - 30 VDC  | Control output<br>No mark: NPN open collector output<br>P: PNP open collector output |  |
| Sold Separately   |  |  |
|   | Bracket: BK-BR-A<br>И12 connector cable: C□D(H)4-□-□                                 |  |


#### **Cautions during Installation**

- Be sure to install this product by following the usage environment, location, and specified ratings. Consider the listed conditions below.
- Installation environment and background (reflected light)
- Sensing distance and sensing target
- Direction of target's movement
- Characteristic curves
- · When installing multiple sensors closely, it may result in malfunction due to mutual interference.
- For installation, tighten the screw with a torque of 0.39 N m. Mount the brackets correctly to prevent the twisting of the sensor's optical axis.
- · Do not impact with a hard object or bend the cable excessively. That could decrease the product's water resistance.
- Use this product after the test. Check whether the indicator works appropriately for the positions of the detectable object.



### **Operation Timing Chart and Indicators**

#### Light ON mode




### Connections



10-30 VDC=


Cable type: Receiver, Polarized retroreflective,





#### Connector type






#### Operation mode selection


 $\underline{\mathbb{A}}$  Be sure to connect the control wire when selecting the operation mode. Failure to this instruction may result in product damage.

- Operation mode Wiring Connect the control wire (white) to +V (brown) Dark ON
- Light ON Connect the control wire (white) to 0 V (Blue)

# Circuit

#### NPN open collector output PNP open collector output






OCP (over current protection), SCP (short circuit protection)
 If short-circuit the control output terminal or supply current over the rated specification, normal control signal is not output due to the protection circuit.


# Sensitivity Adjustment

- Set the adjuster for stable Light ON area, minimizing the effect of the installation environment.
  Use the offered adjustment screwdriver. Do NOT turn with excessive force to prevent
- product damage. The stops below are based on Light ON mode. Thes

| STEP | Status      | Description |   |
|------|-------------|-------------|---|
| 01   | Received    |             | Turn the adjuster from MIN to MAX sensitivity and check the<br>position (A) where the operation indicator activates under the<br>light ON area.   |
| 02   | Interrupted |             | Turn the adjuster from (A) to MAX and check the position (B)<br>where the operation indicator activates under the light OFF area.<br>If the operation indicator does NOT activate at the MAX (maximum<br>sensitivity); MAX = (B). |
| 03   | -           | MIN MAX     | Set the adjuster at the mid position between (A) and (B) for optimal sensitivity.   |

### Dimensions





#### Specifications

|                                   |   |          |                            | ,                               |        |        |
|-----------------------------------|---|----------|----------------------------|---------------------------------|--------|--------|
| Model                             | BRQPS   |          | BRQPS3M-PDTA-              | BRQPS -DDTA                     |        |        |
| Sensing type                      | Through-beam  |          | Polarized retroreflective  | Diffuse reflective              |        |        |
| Sensing distance                  | 10 m  | 20 m     | 3 m 01)                    | 100 mm                          | 400 mm | 700 mm |
| Sensing target                    | Opaque ma   | iterials | Opaque materials           | Opaque, translucent materials   |        |        |
| Min. sensing target               | ≥Ø7mm   |          | ≥ Ø 75 mm                  | -                               |        |        |
| Hysteresis                        | -   |          | -                          | $\leq$ 20 % of sensing distance |        |        |
| Response time                     | ≤1 ms   |          |                            |                                 |        |        |
| Light source                      | Red   |          | Red                        | Red                             |        |        |
| Peak emission<br>wavelength       | 660 nm  |          | 660 nm                     | 660 nm                          |        |        |
| Sensitivity adjustment            | YES (Adjuster)  |          | YES (Adjuster)             | YES (Adjuster)                  |        |        |
| Mutual interference<br>prevention | -   |          | YES                        | YES                             |        |        |
| Operation mode                    | Light ON mode - Dark ON mode selectable (Control wire)                              |          |                            |                                 |        |        |
| Indicator                         | Operation indicator (yellow), stability indicator (green), power indicator (red) 04 |          |                            |                                 |        |        |
| Approval                          | C € 25 c <b>91</b> us EAE   |          | C 든 분K <b>- 위시</b> ::: EAE | C E K 8 8 8 8 8 8               |        |        |

01) Reflector (MS-2S)

02) Non-glossy white paper  $100 \times 100$  mm

03) Non-glossy white paper 200  $\times$  200 mm

04) Only for the emitter

| Unit weight (packaged)            | Through-beam  | Polarized retroreflective,<br>Diffuse reflective |  |  |
|-----------------------------------|---|--|--|--|
| Cable type                        | ≈ 120 g (≈ 170 g)   | ≈ 70 g (≈ 130 g)                                 |  |  |
| Connector type                    | ≈ 35 g (≈ 120 g)  | ≈ 25 g (≈ 120 g)                                 |  |  |
|                                   |   |  |  |  |
| Power supply                      | 10-30 VDC= $\pm 10$ % (ripple P-P: $\leq 10$ %)   |  |  |  |
| Current consumption               | It depends on the sensing type  |  |  |  |
| Through-beam                      | Emitter: $\leq$ 20 mA, receiver: $\leq$ 20 mA   |  |  |  |
| Reflective                        | ≤ 30 mA   |  |  |  |
| Control output                    | NPN open collector output / PNP open collector output model                               |  |  |  |
| Load voltage                      | $\leq$ 30 VDC==   |  |  |  |
| Load current                      | ≤ 100 mA  |  |  |  |
| Residual voltage                  | NPN: $\leq 2$ VDC=, PNP: $\leq 2$ VDC=  |  |  |  |
| Protection circuit                | Reverse power/output protection circuit, output short overcurrent protection circuit      |  |  |  |
| Insulation resistance             | $\geq$ 20 M $\Omega$ (500 VDC= megger)  |  |  |  |
| Noise immunity                    | $\pm$ 240 VDC== the square wave noise (pulse width: 1 µs) by the noise simulator          |  |  |  |
| Dielectric strength               | Between the charging part and the case: 1,000 VAC $\sim$ 50/60 Hz for 1 min               |  |  |  |
| Vibration                         | 1.5 mm double amplitude at frequency of 10 to 55 Hz in each X, Y, Z direction for 2 hours |  |  |  |
| Shock                             | 500 m/s <sup>2</sup> ( $\approx$ 50 G) in each X, Y, Z direction for 3 times              |  |  |  |
| Ambient illuminance<br>(receiver) | Sunlight: ≤ 11,000 lx, incandescent lamp: ≤ 3,000 lx                                      |  |  |  |
| Ambient temperature               | -25 to 60 °C, storage: -30 to 70 °C (no freezing or condensation)                         |  |  |  |
| Ambient humidity                  | 35 to 85 %RH, storage: 35 to 85 %RH (no freezing or condensation)                         |  |  |  |
| Protection rating                 | IP67 (IEC standard)   |  |  |  |
| Connection                        | Cable type / Connector type model   |  |  |  |
| Cable spec.                       | Ø 4 mm, 4-wire, (Emitter: 2-wire), 2 m  |  |  |  |
| Wire spec.                        | AWG26 (0.52 mm, 20-core), insulator outer diameter: Ø 1 mm                                |  |  |  |
| Connector                         | M12 4-pin plug type   |  |  |  |
| Material                          | Case: PC, lens and lens cover: PMMA   |  |  |  |