**Cylindrical Capacitive Proximity Sensors** 

# CR Series (AC 2-wire)

INSTRUCTION MANUAL

TCD210256AB

**Autonics** 

Thank you for choosing our Autonics product.

Read and understand the instruction manual and manual thoroughly before using the product.

For your safety, read and follow the below safety considerations before using. For your safety, read and follow the considerations written in the instruction manual, other manuals and Autonics website.

Keep this instruction manual in a place where you can find easily.

The specifications, dimensions, etc. are subject to change without notice for product improvement. Some models may be discontinued without notice.

Follow Autonics website for the latest information.

# **Safety Considerations**

- Observe all 'Safety Considerations' for safe and proper operation to avoid hazards.
- A symbol indicates caution due to special circumstances in which hazards may occur.

**Warning** Failure to follow instructions may result in serious injury or death.

01. Fail-safe device must be installed when using the unit with machinery that may cause serious injury or substantial economic loss. (e.g. nuclear power control, medical equipment, ships, vehicles, railways, aircraft, combustion apparatus, safety equipment, crime/disaster prevention devices, etc.)

Failure to follow this instruction may result in personal injury, economic loss or fire.

02. Do not use the unit in the place where flammable/explosive/corrosive gas, high humidity, direct sunlight, radiant heat, vibration, impact, or salinity

Failure to follow this instruction may result in explosion or fire.

03. Do not disassemble or modify the unit.

Failure to follow this instruction may result in fire

04. Do not connect, repair, or inspect the unit while connected to a power

Failure to follow this instruction may result in fire.

05. Check 'Connections' before wiring.

Failure to follow this instruction may result in fire.

▲ Caution Failure to follow instructions may result in injury or product damage.

01. Use the unit within the rated specifications.

Failure to follow this instruction may result in fire or product damage

02. Use a dry cloth to clean the unit, and do not use water or organic solvent. Failure to follow this instruction may result in fire.

#### **Cautions during Use**

- Follow instructions in 'Cautions during Use'. Otherwise, it may cause unexpected accidents.
- Wire as short as possible and keep away from high voltage lines or power lines, to prevent surge and inductive noise

Do not use near the equipment which generates strong magnetic force or high frequency noise (transceiver, etc.).

In case installing the product near the equipment which generates strong surge (motor, welding machine, etc.), use diode or varistor to remove surge.

- Do not connect capacity load to the output terminal directly.
- This unit may be used in the following environments
- Indoors (in the environment condition rated in 'Specifications')
- Altitude max. 2,000 m
- Pollution degree 2
- Installation category II

# **Cautions for Installation**

- Install the unit correctly with the usage environment, location, and the designated specifications.
- Do NOT impacts with a hard object or excessive bending of the wire lead-out. It may cause damage the water resistance.
- Do NOT pull the Ø 3.5 mm cable with a tensile strength of 25 N, the Ø 4 mm cable with a tensile strength of 30 N or over and the Ø 5 mm cable with a tensile strength of 50 N or over. It may result in fire due to the broken wire.
- When extending wire, use AWG 22 cable or over within 200 m.

# **Ordering Information**

This is only for reference, the actual product does not support all combinations. For selecting the specified model, follow the Autonics website.

CR 0 - 2 3 4

O DIA. of sensing side Sensing distance

Number: DIA. of sensing side (unit: mm)

Number: Sensing distance (unit: mm) Control output

O: Normally Open C: Normally Closed

## **Product Components**

O Power supply

A: 100 - 240 VAC $\sim$ 

	Product	Instruction manual	Nut	Washer
CR18	× 1	× 1	× 2	-
CR30	× 1	× 1	× 2	× 1


## Sold Separately

- M12 Connector cable: C□A(H)2-□
- Fixed bracket: P90-R□
- Spatter protection cover: P90-M□


## Connections

- LOAD can be wired to any direction.
- · Connect LOAD before suppling the power.

### ■ Cable type



#### ■ Inner circuit



# **Operation Timing Chart**

	Normally open	Normally closed
Sensing target	Presence	Presence
Selising target	Nothing — L	Nothing — L
Load	Operation	Operation
Loau	Return — L	Return L
Operation	ON	ON
indicator (red)	OFF — L	OFF L.

#### Grounding

- The sensing distance is varied by grounding status of the capacity proximity sensor or the target. Check the material when installing the sensor and selecting the target.
- When the capacity proximity sensor and the target are grounded, the electric field is concentrated on the detection surface and the sensing distance may increase.
- If it is not grounded, the electric field radiates to the sensing surface in various directions, and the target is continuously charged with electric charge, the sensing distance may be shorten.

## ■ CR18-8A□









## **Specifications**

Installation Non-flush type			
Model	CR18-8A□	CR30-15A□	
DIA. of sensing side	Ø 18 mm	Ø 30 mm	
Sensing distance 01)	8 mm	15 mm	
Setting distance	0 to 5.6 mm	0 to 10.5 mm	
Hysteresis	≤ 20 % of sensing distance		
Standard sensing target: iron	50 × 50 × 1 mm		
Response frequency 02)	20 Hz		
Affection by temperature	$\leq$ $\pm$ 20 % for sensing distance at ambient temperature 20 °C		
Indicator	Operation indicator (red)		
Approval	EHC	ERC	
Unit weight (package)	≈ 70 g (≈ 82 g)	≈ 200 g (≈ 237 g)	

- 01) Based on grouding status of the standard target.
- 02) The response frequency is the average value. The standard sensing target is used and the width is set as 2 times of the standard sensing target, 1/2 of the sensing distance for the distance.

<b>Power supply</b> 100 -240 VAC ~ 50 / 60 Hz, operating voltage: 85 - 264 VAC ~		
Leakage current	≤ 2.2 mA	
Control output	≤ 5 to 200 mA	
Residual voltage	≤ 20 V	
Protection circuit	Surge protection circuit	
Insulation resistance	≥ 50 MΩ (500 VDC== megger)	
Dielectric strength	Between the charging part and the case : 1,500 VAC $\sim$ 50 / 60Hz for 1 min	
Vibration	1 mm double amplitude at frequency 10 to 55 Hz in each X, Y, Z direction for 2 hours	
Shock	500 m/s² (≈ 50 G) in each X, Y, Z direction for 3 times	
Ambient temperature	-25 to 70 °C, storage: -30 to 80 °C (no freezing or condensation)	
Ambient humidity	35 to 95 %RH, storage: 35 to 95 %RH (no freezing or condensation)	
Protection structure	DIA. of sensing side Ø 18 mm: IP66 (IEC standard) / DIA. of sensing side Ø 30 mm: IP65 (IEC standard)	
Connection	Cable type	
Cable spec.	DIA. of sensing side Ø 18 mm: Ø 4 mm, 2-wire, 2 m DIA. of sensing side Ø 30 mm: Ø 5 mm, 2-wire, 2 m	
Wire spec.	AWG 22 (0.08 mm, 60-core), insulator DIA.: Ø 1.25 mm	
Material	Standard type cable (black): polyvinyl chloride (PVC)	
DIA. of sensing side Ø 18 mm	Case / Nut: PA6	
DIA. of sensing side Ø 30 mm	Case / Nut: nickel-plated brass, washer: nickel-plated iron, sensing side: PBT	

## Sensitivity Adjustment


Please turn potention VR to set sensitivity as below procedure.

- When there is distance fluctuation between proximity sensor and the target, please adjust 2 at the farthest distance from this unit.
- Turning potention VR toward clockwise, it will be max., or turning toward counter clockwise, it will be min. The number of adjustment should be 15  $\pm$  3 revolution and if it is turned to the right or left excessively, it will not stop, but it idles without breakdown.
- ( ) is for Normally closed type.

Procedure	Potention VR	Description
1	Stop at ON (OFF) position	Without a sensing object, turn the potention VR to the right and stop at the proximity sensor is ON (OFF).
2	Stop at OFF (ON) position	Put the object in right sensing position, turn the potention VR to the left and stop at the proximity sensor is OFF (ON).
3	It is stable when it is over 1.5 times  OFF (ON) ON (OFF) position position	If the difference of the number of potention VR rotation between the ON (OFF) point and the OFF (ON) point is more than 1.5 turns, the sensing operation will be stable.
4	Adjustment completed  OFF (ON) ON (OFF) position position	If it is set in sensitivity adjustment position of potention VR at center between 1 and 2, sensitivity setting will be completed.

## **Cut-out Dimensions**

• Unit: mm, For the detailed drawings, follow the Autonics web site



	Ø 18 mm	Ø 30 mm
Mounting hole (H)	Ø 18.5 <sup>+0.5</sup> <sub>0</sub>	Ø 30.5 <sup>+0.5</sup> <sub>0</sub>
TAP	M18×1	M30×1.5




Ø 18 mm	Ø 30 mm
26.5	42
24	35
	26.5

#### Mutual-interference & Influence by Surrounding Metals

#### **■** Mutual-interference

When plural proximity sensors are mounted in a close row, malfunction of sensor may be caused due to mutual interference.

Therefore, be sure to provide a minimum distance between the two sensors, as below



### ■ Influence by surrounding metals

When sensors are mounted on metallic panel, it must be prevented sensors from being affected by any metallic object except target. Therefore, be sure to provide a minimum distance as below chart.









		(unit: mm)
Sensing side	Ø 18 mm	Ø 30 mm
A	48	90
В	54	90
l	20	10
Ød	54	90
m	24	45
n	54	90

## **Tightening Torque**

Use the provided washer to tighten the nuts.

The tightening torque of the nut varies with the distance from the fore-end. [Figure 1] If the nut tip is located at the front of the product, apply the front tightening torque. the allowable tightening torque table is for inserting the washer as [Figure 2].





Sensing side Strength	Ø 18 mm	Ø 30 mm
Front size	-	12 mm
Front torque	0.39 N m	49 N m
Rear torque	0.39 N m	78.4 N m

18, Bansong-ro 513Beon-gil, Haeundae-gu, Busan, Republic of Korea, 48002 www.autonics.com | +82-2-2048-1577 | sales@autonics.com